

CALIFORNIA DEPARTMENT OF FORESTRY & FIRE PROTECTION  
OFFICE OF THE STATE FIRE MARSHAL  
FIRE ENGINEERING - BUILDING MATERIALS LISTING PROGRAM

# LISTING SERVICE

**LISTING No.** 3225-0368:114

Page 1 of 1

**CATEGORY:** Fire Dampers

**LISTEE:** Pottorff, \*2824 N. Sylvania Ave., Fort Worth, TX 76111  
Contact: Michael Beaver (817) 831-7038

**DESIGN:** Models VFD-15R and VFD-35R round fire dampers. Unit constructed of No. 22 Ga. galvanized steel frame, blades and blade hinge with a 165° F or 212° F fusible link. Refer to listee's data sheet for detailed product description and operational considerations.

**RATING:** VFD-15R: 1-1/2 Hr.  
VFD-35R: 3 Hr.  
Single Section Size: minimum 6" and maximum 20" in diameter

**INSTALLATION:** In accordance with listee's printed installation instructions, applicable codes and ordinances and in a manner acceptable to the authority having jurisdiction.

**MARKING:** Listee's name, model number, fire rating and UL label.

**APPROVAL:** Listed as fire rated dampers for use in heating, ventilating and air conditioning duct systems passing through fire resistive walls and partitions. Model VFD-15R is intended for vertical and horizontal mount. Model VFD-35R is intended for vertical mount only.

**NOTE:** Leakage rating not evaluated. Refer to CSFM Listing Category 3230 for leakage rated dampers.

\*Rev 06-15-99



This listing is based upon technical data submitted by the applicant. CSFM Fire Engineering staff has reviewed the test results and/or other data but does not make an independent verification of any claims. This listing is not an endorsement or recommendation of the item listed. This listing should not be used to verify correct operational requirements or installation criteria. Refer to listee's data sheet, installation instructions and/or other suitable information sources.

Date Issued:

**MAY 15, 2002**

*Listing Expires **June 30, 2003***

Authorized By:

**DIANE K. AREND**, Senior Deputy  
Program Manager